

SUPPLIER DECLARATION OF CONFORMITY

(In accordance with ISO/IEC 1750-1:2004)

| | |
|------------------------------------|---|
| SDoC Identification Number: | VYN DEL SERIES CONDUIT FITTING ELBOW:27/07/16 |
|------------------------------------|---|


| SUPPLIER DETAILS | |
|---|---|
| Name: VYNCO INDUSTRIES (NZ) LTD | NZ Company Number: CH506239 03 July 1991 |
| Address: 388 Tuam St, Christchurch 8011 | Website: www.vynco.co.nz |
| Phone: (03) 379 9283 | |
| Fax: (03) 379 6838 | |

| SUPPLIER DETAILS | |
|---|---|
| Name: PDC | Website: www.pdc.co.nz |
| Address: 388 Tuam St, Christchurch 8011 | |
| Phone: (03) 335 0366 | |
| Fax: (03) 335 0980 | |

| PRODUCT DETAILS | | |
|-----------------|---|-----------------|
| Product Code | Description | Type |
| DEL20 AND DEL25 | VYNCO CONDUIT FITTING ELBOW 20MM AND 25MM | CONDUIT FITTING |

| The medium-risk article listed above fully complies with the following standards: | | | |
|---|--|--------------|------|
| AS/NZS 61386.1:2015 – TESTS 10.3 AND 10.7. | CONDUIT SYSTEMS FOR CABLE MANAGEMENT - PART 1 GENERAL REQUIREMENTS | STANDARDS NZ | 2015 |
| IEC 60529.2.2: 2013-08 | DEGREE OF PROTECTION PROVIDED BY ENCLOSURES(IP CODE) – IP52 | IEC | 2013 |

| Test Reports/Certificates that support this declaration: | | | |
|--|---|-----------------------|------------|
| INZ52274-02 | SGS TEST CERTIFICATE – IMPACT TEST MEDIUMDUTY AND PULL OUT STRENGTH | SGS INDUSTRIAL NZ LTD | 02/10/2015 |
| OV-2015-80014 | TEST REPORT – IP52 DEGREE OF PROTECTION | SGS TAIWAN LTD | 01/09/2015 |

| DECLARATION | |
|--|--|
| <p>I hereby declare that the above specified fittings or electrical appliances comply with the requirements of Regulation 69 of the Electricity Regulations 1997.</p> <p>Supplier Identification (as affixed to the product) dp don elbow</p> | <p>Signature of authorised person:</p>  <p>Name: John Vale Position: CEO</p> |